

Solargenossenschaft Gugger-Sunne, Ettingen

## PV-Anlage (60,1 kWp) "Röm. Kath. Kirche", Ettingen

### Produktionszahlen Solarstrom

	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034
Jan		2 448	2 000	2 033	1 881	1 892	2 171	3 413	1 308	2 584	1 272	1 613										
Feb		3 500	2 811	2 260	3 484	2 804	5 565	4 104	3 712	3 920	3 752	2 394										
Mär	50	7 445	6 025	4 958	6 596	3 878	6 422	6 655	6 140	7 484	4 845	3 908										
Apr	1 496	7 062	7 988	5 583	7 570	7 810	5 834	9 121	7 559	6 951	5 217											
Mai	5 267	7 361	7 275	6 925	7 745	7 004	7 160	7 621	6 634	7 920	6 820											
Jun	7 918	8 533	7 535	6 327	8 700	8 340	7 943	7 165	7 353	7 199	8 465											
Jul	8 861	6 693	9 004	7 966	7 463	8 163	8 585	8 652	6 210	9 090	7 332											
Aug	8 410	6 377	7 619	8 387	7 600	7 807	8 033	6 797	6 082	8 006	6 267											
Sep	5 784	6 547	6 325	6 694	5 552	7 394	6 895	6 620	6 599	5 640	7 086											
Okt	4 284	4 791	4 271	3 796	5 445	5 247	3 820	3 157	5 103	4 441	4 539											
Nov	1 938	2 643	3 593	2 362	2 131	2 277	1 992	3 420	1 703	2 354	1 576											
Dez	3 380	1 088	3 611	3 542	1 371	1 523	2 164	1 299	1 648	1 074	1 676											
	47 388	64 488	68 057	60 833	65 538	64 139	66 584	68 024	60 051	66 663	58 847	7 915	0	0	0	0	0	0	0	0	0	0

Gemäss Planung 2012 - Erwarteter Jahresertrag; 58'000 kWh

- = Anlagedefekt 20./21.7. Verlust von ca. 425 kWh  
 = 1 WR-Ausfall während 1 1/2 Tagen